

# DVP-SLIM

## Instruction Sheet 安裝說明書

Digital I/O Extension Unit

數位I/O擴充機

數字I/O擴展機

2018-07-20



Model name	Power supply	Input		Output		Dimension (mm)	Outline
		Points	Type	Points	Type		
DVP08SM11N	24VDC	8	DC Type	0		25.2 90 60	
DVP16SM11N		8	Sink/Source	0			
DVP06SN11R		0		6	Relay		
DVP08SN11R		0		8			
DVP08SN11T		0		16	Transistor (Sink)		
DVP16SN11T		0		8	Transistor (Source)		
DVP08SN11TS		0		16			
DVP16SN11TS		0		0			
DVP08SM10N		8	100 ~ 120VAC	0	N/A		


## 2 Specifications

### ■ Electrical Specifications

Model Item	08SM11N	16SM11N	08SN11R/T/TS	08SP11R/T/TS	16SP11R/T	16SP11TS	08SN11R	16SN11T/TS
(Power supply voltage)								
24VDC (-15%~20%) (with DC input polarity reverse protection)								
(Motion specification)								
Within 5ms of the momentary power loss, the device will keep on operating								
(Power consumption)								
1W 2W 1.5W 1.5W 2W 2W 1.5W 1W								
(Insulation resistance)								
> 5MΩ (all I/O point-to-ground: 500VDC)								
(Noise immunity)								
ESD (IEC 61131-2, IEC 61000-4-2): 8kV Air Discharge								
EFT (IEC 61131-2, IEC 61000-4-4): Power Line: 2kV, Digital I/O: 1kV,								
Analog & Communication I/O: 1kV								
Damped-Oscillatory Wave: Power Line: 1kV, Digital I/O: 1kV								
RS (IEC 61131-2, IEC 61000-4-3): 26MHz ~ 1GHz 10V/m								
(Earth)								
The diameter of grounding wire shall not be less than that of L, N terminal of the power. When many PLCs are in use at the same time, please make sure every PLC is properly grounded.								
(Operation / storage environment)								
Operation: 0°C ~ 55°C (temperature), 5% ~ 95% (humidity), pollution degree 2								
Storage: -25°C ~ 70°C (temperature), 5% ~ 95% (humidity)								
(Shock / vibration immunity)								
International standards: IEC61131-2, IEC 68-2-6 (TEST Fc) / IEC61131-2 & IEC 68-2-27 (TEST Ea)								
(Weight (g))								
162 / 141 146 154 / 146 141 / 136 162 / 154 151 200 70								


### ■ I/O Point Specifications

Input Point		
Input point type	DC	AC
Input type	DC Type (Sink or Source)	-
Input resistance	-	19Kohm/50Hz 16Kohm/60Hz
Input current/voltage	24VDC 5mA	85 ~ 132VAC, 50 ~ 60Hz 9.2mA, 110VAC/60Hz
Active level	Off → On: more than 16.5VDC On → Off: less than 8VDC	More than 79VAC Less than 30VAC
Response time	Approx. 10ms	Off → On < 15ms On → Off < 20ms
Circuit isolation / operation instruction	By photocoupler / LED On	




### ■ Connection


Step 1 Screw open the side cover of the extension unit, and you will see the connection port.




Step 2 Lift the fixing clip by the screwdriver.



Step 3 Adjust the positioning hole of the MPU and the extension unit. Meet the connection port on the MPU with the extension unit to tightly connect the two.



Step 4 Fasten the fixing clip on the extension unit to complete the connection.



### ■ Installation & Wiring

Install the PLC in an enclosure with sufficient space around it to allow heat dissipation (as shown in the figure below).

**How to install DIN rail**  
DVP-PLC can be secured to a cabinet by using the DIN rail of 35mm in height and 7.5mm in depth. When mounting PLC to the DIN rail, be sure to use the end bracket to stop any side-to-side movement of the PLC and reduce the chance of wires being loosen. A small retaining clip is at the bottom of the PLC. To secure PLC to the DIN rail, place the clip onto the rail and gently push it up. To remove it, pull the retaining clip down and gently remove the PLC from the DIN rail.

**Wiring**  
1. Use 22-16AWG (1.5mm) single or multiple core wire on I/O wiring terminals. The specification of the terminal is shown in the figure on the left hand side. The PLC terminal screws shall be tightened to 1.95kg-cm (1.7 in-lbs). Use 65/75°C copper wires only.  
2. DO NOT place the I/O signal wires and power supply wire in the same wiring duct.

### ■ Notes

- DO NOT install PLC in an environment with
  - Dust, smoke, metallic debris, corrosive or flammable gas
  - High temperature, humidity
  - Direct shock and vibration

▪ During the engineering

1. DO NOT drop tiny metallic conductor into the PLC when screwing and wiring.
2. There should be a margin of more than 50mm between the PLC and other control devices, and the PLC should be placed away from high voltage wire and power equipment.


\*1: There is no internal protection circuit in the output relay of the PLC; therefore when activating an inductive load, we suggest you parallelly connect a reverse current protection diode to extend the life of the contact.

- The diode has to be able to endure max. 5 ~ 10 times of load voltage.


\*2: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.

\*3: There is no internal protection circuit in the output relay of the PLC; therefore when activating an inductive load, we suggest you parallelly connect a surge absorber (0.1μF + 100ohm to 120ohm) to reduce the noise on AC load and extend the life of the contact.

### Transistor Output Wiring Circuit (Sink):



- ① DO NOT wire empty terminal
- ② Emergency stop
- ③ Fuse
- ④ Manual exclusive output\*
- ⑤ DC power supply
- ⑥ Incandescent light (resistive load)
- ⑦ Reverse current protection diode\*
- ⑧ Inductive load
- ⑨ Resistive load
- ⑩ Y1, Y3 (refer to other wiring methods)




- ① Y6, Y7 (refer to other wiring methods)
- ② Emergency stop
- ③ Fuse
- ④ Manual exclusive output\*
- ⑤ DC power supply
- ⑥ Incandescent light (resistive load)
- ⑦ Reverse current protection diode\*
- ⑧ Inductive load
- ⑨ Resistive load

\*1: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.

\*2: Use a zener diode (39V) in the PLC to protect the transistor output. When activating inductive load, we suggest you parallelly connect a reverse current protection diode.

### Transistor Output Wiring Loop (Source):



- ① Y6, Y7 (refer to other wiring methods)
- ② Emergency stop
- ③ Fuse
- ④ Manual exclusive output\*
- ⑤ DC power supply
- ⑥ Incandescent light (resistive load)
- ⑦ Reverse current protection diode\*
- ⑧ Inductive load
- ⑨ Resistive load

\*1: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.

\*2: Use a zener diode (39V) in the PLC to protect the transistor output. When activating inductive load, we suggest you parallelly connect a reverse current protection diode.

## Warning

### ENGLISH

EN DVP-SLIM is an OPEN-TYPE device. It should be installed in a control cabinet free of airborne dust, humidity, electric shock and vibration. To prevent non-maintenance staff from operating DVP-SLIM, or to prevent an accident from damaging DVP-SLIM, the control cabinet in which DVP-SLIM is installed should be equipped with a safeguard. For example, the control cabinet in which DVP-SLIM is installed can be unlocked with a special tool or key.

EN DO NOT connect AC power to any of I/O terminals, otherwise serious damage

機種	電源	輸入單元		輸出單元		尺寸 (mm)	外形參考
		點數	形式	點數	形式		
DVP16SN11TS		0		16			

## 2 功能規格

### 電氣規格

項目	08SM11N 08SM10N	16SM11N	08SN11R/T /TS	08SP11R/T /TS	16SP11R/T	16SP11TS	06SN11R	16SN11T /TS
電源電壓	24VDC (-15% ~ 20%) (具直流輸入電源極性反接保護)							
動作規格	電源瞬間斷電 5ms 以內繼續運轉							
消耗電力	1W	2W	1.5W	1.5W	2W	2W	1.5W	1W
絕緣阻抗	5 MΩ 以上 (所有輸出 / 入點對地之間 500VDC)							
雜訊免疫力	ESD (IEC 61131-2, IEC 61000-4-2): 8kV Air Discharge EFT (IEC 61131-2, IEC 61000-4-4): Power Line: 2kV, Digital I/O: 1kV, Analog & Communication I/O: 1kV Damped-Oscillatory Wave: Power Line: 1kV, Digital I/O: 1kV RS (IEC 61131-2, IEC 61000-4-3): 26MHz ~ 1GHz, 10V/m							
接地	接地配線之線徑不得小於電源端 L, N 之線徑 (多台 PLC 同時使用時, 請務必單點接地)							
操作 / 儲存環境	操作 : 0°C ~ 55°C (溫度) 5% ~ 95% (濕度), 汚染等級 2 儲存 : -25°C ~ 70°C (溫度) 5% ~ 95% (濕度)							
耐振動 / 衝擊	國際標準規範 IEC61131-2, IEC 68-2-6 (TEST Fc) / IEC61131-2 & IEC 68-2-27 (TEST Ea)							
重量 (約) (g)	162 / 141	146	154 / 146	141 / 136	162 / 154	151	200	70

### 輸入點規格

輸入點電氣規格			
輸入點形式	直流	交流	
輸入形式	直流 (Sink 或 Source)	-	
輸入阻抗	-	19Kohm/50Hz 16Kohm/60Hz	
電壓電流	24VDC 5mA	85~132VAC 50~60Hz 9.2mA 110VAC/60Hz	
動作位準	Off → On : 16.5VDC 以上	79VAC 以上	
	On → Off : 8VDC 以下	30VAC 以下	
反應時間	約 10ms	Off → On < 15ms On → Off < 20ms	
電路隔離 / 操作指示	光耦合器 / LED On		
輸出點電氣規格			
輸出點形式	繼電器-R 繼電器-R (*1)	電晶體-T (Sink) 電晶體-T (Source)	
電流規格	1.5A/1 點 (5A/COM)	6A/1 point 55°C 0.1A/1 點、 50°C 0.15A/1 點、 45°C 0.2A/1 點、 40°C 0.3A/1 點 (2A/COM)	
電壓規格	250VAC, 30VDC 以下	250VAC, 30VDC 以下 30VDC	30VDC
最大負載	*2	*3 9W	9W
反應時間	約 10ms	約 10ms Off → On 15us On → Off 25us	Off → On 15us On → Off 25us

EXT2	08SM11N	8	0	X30 ~ X37	-
EXT3	06SN11R	0	6	-	Y30 ~ Y35
EXT4	08SP11R	4	4	X40 ~ X43	Y40 ~ Y43

第 3 台擴充機 06SN11R 會被視為 8 點輸出, 序號較高的 2 個輸出點則沒有對應實際的輸出點。

第 4 台擴充機 08SP11R 會被視為 8 點輸出, 序號較高的 4 個輸入點及 4 個輸出點則沒有對應實際的輸入/輸出點, 因此建議置於串聯末端, 輸入/出點編號才會連續。

### 輸入端配線及規格

輸入點之人力信號共有兩種：為直流電源 DC 輸入及交流電源 AC 輸入。

DC 型式共有兩種接法, SINK (請參閱英文版[Figure 7]) 及 SOURCE (請參閱英文版[Figure 8])。

#### AC 型式配線



實用之繼電器輸出回路配線 (Sink) (詳細配線圖請參閱英文版 [Figure 9] 及 [Figure 11])

- ① 空端子請勿配線
- ② 保線絲
- ③ 緊急停止：使用外部開關
- ④ 互斥輸出：利用外部電路形成互鎖，配合 PLC 內部程式，確保任何異常突發狀況發生時，均有安全的保護措施。
- ⑤ 直流電源供應
- ⑥ 白熾燈（電阻性負載）
- ⑦ 反向電流保護二極體：在 PLC 的輸出繼電器並沒有內部保護電路，因此若使用在直流電感性負載時，請並聯接上一個反向電流保護二極體，可增加接點壽命。反向電流保護二極體須符合下列規格：必須能承受最大 5 ~ 10 倍的負載電流及正向電流須大於負載電流。
- ⑧ 電感性負載
- ⑨ 白熾燈（電阻性負載）
- ⑩ 直流電源供給
- ⑪ 交流電源供給

實用之電晶體輸出回路配線 (Source) (詳細配線圖請參閱英文版 [Figure 12])

- ① Y6,Y7 可參考其它配線方式
- ② 緊急停止
- ③ 保線絲
- ④ 互斥輸出：利用外部電路形成互鎖，配合 PLC 內部程式，確保任何異常突發狀況發生時，均有安全的保護措施。
- ⑤ 直流電源供應
- ⑥ 白熾燈（電阻性負載）
- ⑦ 反向電流保護二極體：在 PLC 內部使用齊納二極體 (39V) 來保護電晶體輸出，若驅動電感性負載時，建議並聯接上一個反向電流保護二極體。
- ⑧ 電感性負載
- ⑨ 電阻性負載

## 注意事項

✓ 請在使用之前，詳細閱讀本使用說明書。


✓ 本機為開放型 (OPEN TYPE) 机壳，因此使用者使用本机时，必须将其安装于具防尘、防潮及免于电击 / 冲击意外的外壳配线箱内。另必须具备保护措施 (如：特殊的工具或钥匙才可打开) 防止非维护人员操作或意外冲击本体，造成危险及损坏。

✓ 交流输入电源不可连接于直流类型的输入 / 出信号端，否则可能造成严重的损坏，因此请在上电之前再次确认电源配线。请勿在上电时触摸任何端子。

## 產品簡介

謝謝您採用台達 DVP-SLIM 系列可編程控制器。DVP-SLIM 系列 6 ~ 16 點擴展，含主機最大數字輸入 / 輸出擴展分別可達 256 點。另備特殊模塊 (AD/DA/PT/TC/XA/PU) 擴展功能，最多可擴展 8 台特殊模塊。

### 產品外觀及各部介紹



### 機型型号

機種	電源	輸入單元		輸出單元		尺寸 mm	外形參考
點數	形式	點數	形 式	點數	形 式		
DVP08SP11R	24VDC	4		4	繼電器	25.2	
DVP16SP11R		8		8		90	
DVP08SP11T		4		4	晶體管 (Sink)	60	
DVP16SP11T		8		8	晶體管 (Sink)	60	
DVP08SP11TS		4		4	晶體管 (Source)	25.2	
DVP16SP11TS		8		8	晶體管 (Source)	90	
DVP08SM10N		8		0	無	60	
DVP08SM11N		16		0	無	60	
DVP16SM11N		0		6	繼電器	25.2	
DVP06SN11R		0		8		90	
DVP08SN11R		0		8	繼電器	60	
DVP08SN11T		0		8	晶體管 (Sink)	25.2	
DVP16SN11T		0		16	晶體管 (Sink)	90	
DVP08SN11TS		0		8	晶體管 (Source)	60	

\*2: 請參考英文版[Figure 1]

\*3: 請參考英文版[Figure 2]

## 安裝及配線

### 數字 I/O 擴展機的端子配置圖

請參考英文版之端子配置圖。

### 系統組合


步驟 1 利用螺絲起子將擴充側蓋打開，會出現擴充機連接口。(請參閱英文版[Figure 3])

步驟 2 再利用螺絲起子將擴充機固定扣往上撥。(請參閱英文版[Figure 4])

步驟 3 調整好主機和擴充機的定位孔，並且將主機的擴充機連接口與擴充機接合，此時主機與擴充機之間緊密結合。(請參閱英文版[Figure 5])

步驟 4 將擴充機固定扣往下扣住，完成與主機之系統組合。(請參閱英文版[Figure 6])

### 盤內安裝及配線



### 注意事項

- 請勿將 PLC 裝置于
  - 落塵大、油煙、金屬性粉塵及腐蝕性或可燃性氣體的環境
  - 高溫、結露的環境
  - 有直接振動及衝擊的場所

### 施工注意

1. 鎮螺絲及配線時請